



Lighting Sciences, Inc.
UL Verification Services
7826 E. Evans Rd.
Scottsdale, Arizona 85260 USA
P: 480-991-9260 F: 480-991-0375
lsi@ul.com



www.lightingsciences.com

INDEPENDENT TEST LABORATORY REPORT No. 32070

Description:

GLOBAL TECH LED - LED WALL PACK, CAT# GTSOLM21 RETROFIT KIT
WITH WHITE INTERIOR AND CLEAR FLAT GLASS LENS
ONE GLOBALTECHLED GT60-24-120-277 DRIVER OPERATING AT 120 VAC AND 58.8 WATTS

-
-

The sample(s) was(were) tested in accordance with the following applied standards/regulations:

ANSI/UL 1598-2008 Luminaires: In-Situ Temperature Measurement Test (ISTMT)

Prepared for:

GLOBAL TECH LED
NAPLES, FL

Approved by:

JIM DOMIGAN

LABORATORY TEAM LEADER


OCT 7, 2013

This report shall not be reproduced except in full without the written approval of the laboratory. The results in this report apply to the test sample(s) mentioned above at the time of the testing period only and are not to be used to indicate applicability to other similar products.


INDEPENDENT TEST LABORATORY REPORT No. 32070

GLOBAL TECH LED - LED WALL PACK, CAT# GTSOLM21 RETROFIT KIT
WITH WHITE INTERIOR AND CLEAR FLAT GLASS LENS
ONE GLOBALTECHLED GT60-24-120-277 DRIVER OPERATING AT 120 VAC AND 58.8 WATTS

LED Thermocouple Location



Driver Thermocouple Location



Test Temperature:	25.0 °C
LED Temperature:	78.9 °C
Driver Temperature:	54.8 °C
Maximum LED Current:	809 mA

Temperatures are offset to an ambient temperature of 25°C as described in UL1598-2008